



December 18, 2025

Lauren Doherty
Intertek PSI
17 British American Boulevard
Latham, NY 12110

RE: Project: CAPITAL REGION BOCES
Pace Project No.: 70395568

Dear Lauren Doherty:

Enclosed are the analytical results for sample(s) received by the laboratory on December 04, 2025. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in cursive script that reads 'Lori Beyer'.

Lori A. Beyer
lori.beyer@pacelabs.com
516-370-6014
Project Manager

Enclosures

cc: Lauren Doherty, Intertek PSI



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CERTIFICATIONS

Project: CAPITAL REGION BOCES

Pace Project No.: 70395568

Pace Analytical Services, LLC - Melville, NY

575 Broad Hollow Rd, Melville, NY 11747

Connecticut Certification #: PH-0435

Delaware Certification # NY 10478

Maryland Certification #: 208

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

New Jersey Certification #: NY158

New York Certification #: 10478 Primary Accrediting Body

Pennsylvania Certification #: 68-00350

Rhode Island Certification #: LAO00340

Texas Certification #: T104704582

Florida Certification #: E871198

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE SUMMARY

Project: CAPITAL REGION BOCES

Pace Project No.: 70395568

Lab ID	Sample ID	Matrix	Date Collected	Date Received
70395568001	ACTE FF DF 1	Drinking Water	11/26/25 10:05	12/04/25 06:00
70395568002	ACTE FF BF 1	Drinking Water	11/26/25 10:06	12/04/25 06:00
70395568003	ACTE R121 KS 1	Drinking Water	11/26/25 10:10	12/04/25 06:00
70395568004	ACTE R121 KS 2	Drinking Water	11/26/25 10:11	12/04/25 06:00
70395568005	ACTE R121 KS 3	Drinking Water	11/26/25 10:14	12/04/25 06:00
70395568006	ACTE R121 KS 4	Drinking Water	11/26/25 10:15	12/04/25 06:00
70395568007	ACTE R119 KS 1	Drinking Water	11/26/25 10:21	12/04/25 06:00
70395568008	ACTE R119 KS 2	Drinking Water	11/26/25 10:23	12/04/25 06:00
70395568009	ACTE R119 KS 3	Drinking Water	11/26/25 10:24	12/04/25 06:00
70395568010	ACTE R119 KS 4	Drinking Water	11/26/25 10:26	12/04/25 06:00
70395568011	ACTE FF DF 2	Drinking Water	11/26/25 10:32	12/04/25 06:00
70395568012	ACTE FF BF 2	Drinking Water	11/26/25 10:33	12/04/25 06:00
70395568013	ACTE FF DF 3	Drinking Water	11/26/25 10:37	12/04/25 06:00
70395568014	ACTE FF BF 3	Drinking Water	11/26/25 10:39	12/04/25 06:00
70395568015	ACTE FF DF 4	Drinking Water	11/26/25 10:47	12/04/25 06:00
70395568016	ACTE FF BF 4	Drinking Water	11/26/25 10:49	12/04/25 06:00
70395568017	ACTE R115 KS 1	Drinking Water	11/26/25 12:15	12/04/25 06:00
70395568018	ACTE R115 KS 2	Drinking Water	11/26/25 12:16	12/04/25 06:00
70395568019	ACTE R115 KS 3	Drinking Water	11/26/25 12:18	12/04/25 06:00
70395568020	ACTE R112 KS 1	Drinking Water	11/26/25 12:21	12/04/25 06:00
70395568021	ACTE R112 KS 2	Drinking Water	11/26/25 12:24	12/04/25 06:00
70395568022	ACTE R112 KS 3	Drinking Water	11/26/25 12:26	12/04/25 06:00
70395568023	ACTE SF DF 1	Drinking Water	11/26/25 12:29	12/04/25 06:00
70395568024	ACTE SF BF 1	Drinking Water	11/26/25 12:31	12/04/25 06:00
70395568025	ACTE R315 DF	Drinking Water	11/26/25 12:40	12/04/25 06:00
70395568026	ACTE R315 KS	Drinking Water	11/26/25 12:41	12/04/25 06:00
70395568027	ACTE TF DF 1	Drinking Water	11/26/25 12:56	12/04/25 06:00
70395568028	ACTE TF BF 1	Drinking Water	11/26/25 12:58	12/04/25 06:00
70395568029	ACTE R306 KS	Drinking Water	11/26/25 13:05	12/04/25 06:00

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: CAPITAL REGION BOCES

Pace Project No.: 70395568

Lab ID	Sample ID	Method	Analysts	Analytes Reported
70395568001	ACTE FF DF 1	EPA 200.8	JJS	1
70395568002	ACTE FF BF 1	EPA 200.8	JJS	1
70395568003	ACTE R121 KS 1	EPA 200.8	JJS	1
70395568004	ACTE R121 KS 2	EPA 200.8	JJS	1
70395568005	ACTE R121 KS 3	EPA 200.8	JJS	1
70395568006	ACTE R121 KS 4	EPA 200.8	JJS	1
70395568007	ACTE R119 KS 1	EPA 200.8	JJS	1
70395568008	ACTE R119 KS 2	EPA 200.8	JJS	1
70395568009	ACTE R119 KS 3	EPA 200.8	JJS	1
70395568010	ACTE R119 KS 4	EPA 200.8	JJS	1
70395568011	ACTE FF DF 2	EPA 200.8	JJS	1
70395568012	ACTE FF BF 2	EPA 200.8	JJS	1
70395568013	ACTE FF DF 3	EPA 200.8	JP2	1
70395568014	ACTE FF BF 3	EPA 200.8	JP2	1
70395568015	ACTE FF DF 4	EPA 200.8	JP2	1
70395568016	ACTE FF BF 4	EPA 200.8	JP2	1
70395568017	ACTE R115 KS 1	EPA 200.8	JP2	1
70395568018	ACTE R115 KS 2	EPA 200.8	JP2	1
70395568019	ACTE R115 KS 3	EPA 200.8	JP2	1
70395568020	ACTE R112 KS 1	EPA 200.8	JP2	1
70395568021	ACTE R112 KS 2	EPA 200.8	JP2	1
70395568022	ACTE R112 KS 3	EPA 200.8	JP2	1
70395568023	ACTE SF DF 1	EPA 200.8	JP2	1
70395568024	ACTE SF BF 1	EPA 200.8	JP2	1
70395568025	ACTE R315 DF	EPA 200.8	JP2	1
70395568026	ACTE R315 KS	EPA 200.8	JP2	1
70395568027	ACTE TF DF 1	EPA 200.8	JP2	1
70395568028	ACTE TF BF 1	EPA 200.8	JP2	1
70395568029	ACTE R306 KS	EPA 200.8	JP2	1

PACE-MV = Pace Analytical Services - Melville

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CAPITAL REGION BOCES
Pace Project No.: 70395568

Sample: ACTE FF DF 1		Lab ID: 70395568001		Collected: 11/26/25 10:05		Received: 12/04/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/17/25 12:57	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAPITAL REGION BOCES
Pace Project No.: 70395568

Sample: ACTE FF BF 1		Lab ID: 70395568002		Collected: 11/26/25 10:06		Received: 12/04/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/17/25 12:58	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAPITAL REGION BOCES

Pace Project No.: 70395568

Sample: ACTE R121 KS 1		Lab ID: 70395568003	Collected: 11/26/25 10:10	Received: 12/04/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/17/25 13:00	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CAPITAL REGION BOCES
Pace Project No.: 70395568

Sample: ACTE R121 KS 2		Lab ID: 70395568004		Collected: 11/26/25 10:11		Received: 12/04/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/17/25 13:01	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAPITAL REGION BOCES
Pace Project No.: 70395568

Sample: ACTE R121 KS 3		Lab ID: 70395568005		Collected: 11/26/25 10:14		Received: 12/04/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/17/25 13:02	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAPITAL REGION BOCES
Pace Project No.: 70395568

Sample: ACTE R121 KS 4		Lab ID: 70395568006		Collected: 11/26/25 10:15		Received: 12/04/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/17/25 13:04	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAPITAL REGION BOCES

Pace Project No.: 70395568

Sample: ACTE R119 KS 1		Lab ID: 70395568007		Collected: 11/26/25 10:21		Received: 12/04/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/17/25 13:07	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CAPITAL REGION BOCES

Pace Project No.: 70395568

Sample: ACTE R119 KS 2		Lab ID: 70395568008	Collected: 11/26/25 10:23	Received: 12/04/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/17/25 13:09	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CAPITAL REGION BOCES
Pace Project No.: 70395568

Sample: ACTE R119 KS 3		Lab ID: 70395568009		Collected: 11/26/25 10:24		Received: 12/04/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/17/25 13:10	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAPITAL REGION BOCES
Pace Project No.: 70395568

Sample: ACTE R119 KS 4		Lab ID: 70395568010		Collected: 11/26/25 10:26		Received: 12/04/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/17/25 13:11	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAPITAL REGION BOCES
Pace Project No.: 70395568

Sample: ACTE FF DF 2		Lab ID: 70395568011		Collected: 11/26/25 10:32		Received: 12/04/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/17/25 13:12	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAPITAL REGION BOCES
Pace Project No.: 70395568

Sample: ACTE FF BF 2		Lab ID: 70395568012		Collected: 11/26/25 10:33		Received: 12/04/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/17/25 13:14	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAPITAL REGION BOCES
Pace Project No.: 70395568

Sample: ACTE FF DF 3		Lab ID: 70395568013		Collected: 11/26/25 10:37		Received: 12/04/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/17/25 16:24	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAPITAL REGION BOCES
Pace Project No.: 70395568

Sample: ACTE FF BF 3		Lab ID: 70395568014		Collected: 11/26/25 10:39		Received: 12/04/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/17/25 16:27	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAPITAL REGION BOCES

Pace Project No.: 70395568

Sample: ACTE FF DF 4		Lab ID: 70395568015		Collected: 11/26/25 10:47		Received: 12/04/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/17/25 16:31	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CAPITAL REGION BOCES
Pace Project No.: 70395568

Sample: ACTE FF BF 4		Lab ID: 70395568016		Collected: 11/26/25 10:49		Received: 12/04/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/17/25 16:32	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAPITAL REGION BOCES
Pace Project No.: 70395568

Sample: ACTE R115 KS 1		Lab ID: 70395568017		Collected: 11/26/25 12:15		Received: 12/04/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/17/25 16:36	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAPITAL REGION BOCES
Pace Project No.: 70395568

Sample: ACTE R115 KS 2		Lab ID: 70395568018		Collected: 11/26/25 12:16		Received: 12/04/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/17/25 16:38	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAPITAL REGION BOCES
Pace Project No.: 70395568

Sample: ACTE R115 KS 3		Lab ID: 70395568019		Collected: 11/26/25 12:18		Received: 12/04/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/17/25 16:39	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAPITAL REGION BOCES

Pace Project No.: 70395568

Sample: ACTE R112 KS 1		Lab ID: 70395568020		Collected: 11/26/25 12:21		Received: 12/04/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/17/25 16:40	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CAPITAL REGION BOCES
Pace Project No.: 70395568

Sample: ACTE R112 KS 2		Lab ID: 70395568021		Collected: 11/26/25 12:24		Received: 12/04/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/17/25 16:41	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAPITAL REGION BOCES

Pace Project No.: 70395568

Sample: ACTE R112 KS 3		Lab ID: 70395568022		Collected: 11/26/25 12:26		Received: 12/04/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/17/25 16:43	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CAPITAL REGION BOCES
Pace Project No.: 70395568

Sample: ACTE SF DF 1		Lab ID: 70395568023		Collected: 11/26/25 12:29		Received: 12/04/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/17/25 16:44	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAPITAL REGION BOCES
Pace Project No.: 70395568

Sample: ACTE SF BF 1		Lab ID: 70395568024		Collected: 11/26/25 12:31		Received: 12/04/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/17/25 16:46	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAPITAL REGION BOCES
Pace Project No.: 70395568

Sample: ACTE R315 DF		Lab ID: 70395568025		Collected: 11/26/25 12:40		Received: 12/04/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/17/25 16:48	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAPITAL REGION BOCES

Pace Project No.: 70395568

Sample: ACTE R315 KS		Lab ID: 70395568026		Collected: 11/26/25 12:41		Received: 12/04/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/17/25 16:52	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CAPITAL REGION BOCES

Pace Project No.: 70395568

Sample: ACTE TF DF 1		Lab ID: 70395568027		Collected: 11/26/25 12:56		Received: 12/04/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/17/25 16:53	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CAPITAL REGION BOCES
Pace Project No.: 70395568

Sample: ACTE TF BF 1		Lab ID: 70395568028		Collected: 11/26/25 12:58		Received: 12/04/25 06:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/17/25 16:54	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: CAPITAL REGION BOCES
Pace Project No.: 70395568

Sample: ACTE R306 KS		Lab ID: 70395568029		Collected: 11/26/25 13:05		Received: 12/04/25 06:00		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		12/17/25 16:55	7439-92-1		

REPORT OF LABORATORY ANALYSIS



QUALITY CONTROL DATA

Project: CAPITAL REGION BOCES
Pace Project No.: 70395568

QC Batch:	432994	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70395568001, 70395568002, 70395568003, 70395568004, 70395568005, 70395568006, 70395568007, 70395568008, 70395568009, 70395568010, 70395568011, 70395568012		

METHOD BLANK: 2320833 Matrix: Water
Associated Lab Samples: 70395568001, 70395568002, 70395568003, 70395568004, 70395568005, 70395568006, 70395568007, 70395568008, 70395568009, 70395568010, 70395568011, 70395568012

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/17/25 12:42	

LABORATORY CONTROL SAMPLE: 2320834						
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	47.2	94	85-115	

MATRIX SPIKE SAMPLE:		2320836					
		70397258021	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<2.0	100	85.4	85	70-130	

MATRIX SPIKE SAMPLE:		2320838					
		70397258022	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<2.0	100	87.0	87	70-130	

SAMPLE DUPLICATE: 2320835						
Parameter	Units	70397258021 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<2.0	<2.0		20	

SAMPLE DUPLICATE: 2320837						
Parameter	Units	70397258022 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<2.0	<2.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: CAPITAL REGION BOCES
Pace Project No.: 70395568

QC Batch:	433079	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70395568013, 70395568014, 70395568015, 70395568016, 70395568017, 70395568018, 70395568019, 70395568020, 70395568021, 70395568022, 70395568023, 70395568024, 70395568025, 70395568026, 70395568027, 70395568028, 70395568029		

METHOD BLANK:	2321614	Matrix:	Water
Associated Lab Samples:	70395568013, 70395568014, 70395568015, 70395568016, 70395568017, 70395568018, 70395568019, 70395568020, 70395568021, 70395568022, 70395568023, 70395568024, 70395568025, 70395568026, 70395568027, 70395568028, 70395568029		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/17/25 16:21	

LABORATORY CONTROL SAMPLE:	2321615					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	46.9	94	85-115	

MATRIX SPIKE SAMPLE:		2321617					
		70395568013	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	48.1	96	70-130	

MATRIX SPIKE SAMPLE:	2321619						
		70395568014	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	45.4	91	70-130	

SAMPLE DUPLICATE:	2321616					
Parameter	Units	70395568013 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

SAMPLE DUPLICATE:	2321618					
Parameter	Units	70395568014 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALIFIERS

Project: CAPITAL REGION BOCES
Pace Project No.: 70395568

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: CAPITAL REGION BOCES

Pace Project No.: 70395568

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70395568001	ACTE FF DF 1	EPA 200.8	432994		
70395568002	ACTE FF BF 1	EPA 200.8	432994		
70395568003	ACTE R121 KS 1	EPA 200.8	432994		
70395568004	ACTE R121 KS 2	EPA 200.8	432994		
70395568005	ACTE R121 KS 3	EPA 200.8	432994		
70395568006	ACTE R121 KS 4	EPA 200.8	432994		
70395568007	ACTE R119 KS 1	EPA 200.8	432994		
70395568008	ACTE R119 KS 2	EPA 200.8	432994		
70395568009	ACTE R119 KS 3	EPA 200.8	432994		
70395568010	ACTE R119 KS 4	EPA 200.8	432994		
70395568011	ACTE FF DF 2	EPA 200.8	432994		
70395568012	ACTE FF BF 2	EPA 200.8	432994		
70395568013	ACTE FF DF 3	EPA 200.8	433079		
70395568014	ACTE FF BF 3	EPA 200.8	433079		
70395568015	ACTE FF DF 4	EPA 200.8	433079		
70395568016	ACTE FF BF 4	EPA 200.8	433079		
70395568017	ACTE R115 KS 1	EPA 200.8	433079		
70395568018	ACTE R115 KS 2	EPA 200.8	433079		
70395568019	ACTE R115 KS 3	EPA 200.8	433079		
70395568020	ACTE R112 KS 1	EPA 200.8	433079		
70395568021	ACTE R112 KS 2	EPA 200.8	433079		
70395568022	ACTE R112 KS 3	EPA 200.8	433079		
70395568023	ACTE SF DF 1	EPA 200.8	433079		
70395568024	ACTE SF BF 1	EPA 200.8	433079		
70395568025	ACTE R315 DF	EPA 200.8	433079		
70395568026	ACTE R315 KS	EPA 200.8	433079		
70395568027	ACTE TF DF 1	EPA 200.8	433079		
70395568028	ACTE TF BF 1	EPA 200.8	433079		
70395568029	ACTE R306 KS	EPA 200.8	433079		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CHAIN-OF-CUSTODY Analytical Request Document
Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

LAB USE ONLY - Affix Workorder/Login Label Here



Scan QR Code for instructions

Company Name: Intertek-PSI
Street Address: 17 British American Blvd, Latham, NY 12120

Customer Project #: Capital Region BOCES Facility

Site Collection Info/Facility ID (as applicable):

Contact/Report To: William Kotas
Phone #: (518) 377-9841
E-Mail: william.kotas@intertek.com
Cc E-Mail:

Invoice To: PSI Latham Accounts Payable
Invoice E-Mail: LathamAR@intertek.com

Purchase Order # (if applicable):

Quote #: CR-BOCES 23-057

County / State origin of sample(s): New York

Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead in School DW

Rush (Pre-approval required):

[] 12 Day [] 3 day [] 5 day [] Other

Date Results Requested: Standard 10 business day

Field Filtered (if applicable): [] Yes [] No

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OI), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SD), Sludge (SL), Caulk

Customer Sample ID	Matrix *	Comp / Grab	Collected (or Composite Start)		Composite End		Res. CL2	Number & Type of Containers		200.8 Drinking Water (Pb only)	Preservation non-conformance identified for sample.
			Date	Time	Date	Time		Plastic	Glass		
ACTE. FF. DF 2	DW	G	11.26.25	10:32 am				1		X	
ACTE. FF. BF 2				10:33 am				1		X	
ACTE. FF. DF 3				10:37 am				1		X	
ACTE. FF. BF 3				10:39 am				1		X	
ACTE. FF. DF 4				10:47 am				1		X	
ACTE. FF. BF 4				10:49 am				1		X	
ACTE. R115. KS 1				12:15 pm				1		X	
ACTE. R115. KS 2				12:16 pm				1		X	
ACTE. R115. KS 3				12:18 pm				1		X	
ACTE. R112. KS 1				12:21 pm				1		X	

Customer Remarks / Special Conditions / Possible Hazards:
Lead NY Schools

Additional Instructions from Pace®:

Relinquished by/Company: (Signature)	Date/Time: 11-26-25 1500	Thermometer ID: T1211	Correction Factor (°C): F.	Obs. Temp. (°C): 18.1	Corrected Temp. (°C): 18.2
Relinquished by/Company: (Signature)	Date/Time: 12/3/25 1600	Tracking Number:			
Relinquished by/Company: (Signature)	Date/Time: 12/3/25 1605	Delivered by: [] In-Person [] Courier			
Relinquished by/Company: (Signature)	Date/Time: 12/4/25 16:00	[] FedEx [] UPS [] Other			
Relinquished by/Company: (Signature)	Date/Time:	Page: of			



Client:

Profile #:

Work ID:

bc Page

of

Use Point Number Spreadsheet

Multiday Project

Add SCLOGFD to first sample for field charge

WO#: 70395568

PM: 10R Due Date: 12/18/25

CLIENT: INTER-LATHAM

[illegible]

Colors	Glass		Plastic		
WG9U	40mL unpres clear vial	AG4U	125mL unpres amber glass	BP4U	125mL unpres plastic
WG9C	40mL Ascorbic-HCl clear vial	AG3U	250mL unpres amber glass	BP3U	250mL unpres plastic
WG9H	40mL HCl clear vial	AG2U	500mL unpres amber glass	BP2U	500mL unpres plastic
WG9S	40mL Sulfuric clear vial	AG1U	1liter unpres amber glass	BP1U	1L unpres plastic
WG9T	40mL Na Thiosulfate vial	AG34	Ammonium Cl 250mL bottle	BP4N	250mL HNO3 plastic
DG9V	40mL Citrate-Na Thiosulfate	AG3S	250mL H2SO4 amber glass	BP3N	250mL HNO3 plastic
DG9P	40mL amber vial - TSP	AG4E	125mL EDA amber glass	BP2N	500mL H2SO4 plastic
DG9A	Ascorbic/Maleic Acid 40mL	AG3T	250mL Na Thio amber glass	BP3S	250mL H2SO4 plastic
DG6T	Na Thio 60mL Vial	AG2R	Na Sulfite 500mL (blue Cap)	BP2S	500mL H2SO4 plastic
DG9S	Ammonium Cl/Cu/NaSO4 40mL	AG1H	Na Thiosulfate 1L bottle	BP3C	NaOH 250mL bottle
CG1U	1L Unpres Jar (Con Ed)	AG1T	1L HCl amber glass	BP3T	250mL Trizma
WG80	8oz clear soil jar	AG1A	(NH4Cl)	BP3S	250mL Ammonium Acetate
WG40	4oz clear soil jar	AG5U	100mL unpres Amber Glass	BP3R	250mL NH4SO4-NH4OH
		AG44	Ammonium Cl 120mL bottle	BP1Z	1L NaOH, Zn Acetate
				BP1N	1L HNO3 plastic
				BP1R	Na Thiosulfate Amber Bottle

	Misc.
PS5T	120mL Coliform Na Thio
R	Terracore Kit
W62U	2oz Unpreserved Jar
WG6U	4oz Unpreserved Jar
WGKU	8oz Unpreserved Jar
WGDU	16oz Unpreserved Jar
PLCU	Ziplock Bag
TEDL	Tedlar Bag
BG1H	1 L HCL Clear Glass
BGN	General
WP	Wipe
	Low Level Hq Bottles
BG3N	1L HNO3 Clear Glass

IOC	
BP1U	1L unpreserved plastic
BP3N*	250mL HNO3 plastic
BP3C	250mL Sodium Hydroxide
AG2U	500mL unpres amber glass
BP3U	250mL unpreserved plastic

* Can also be a BP4N

Matrix	
WT	Water
SL	Solid
NAL	Non-aqueous Liquid
OL	OIL
WP	Wipe
DW	Drinking Water

SOC	
V99T	40mL Na Thio amber vial
DG9A	40mL Acetic acid malic Acid vials
DG9Y	Citrate/Na Thiosulfate 40mL
DG8T	Na Thiosulfate 60mL vial
DG6T	MonoChlorate/Na Thio 60mL
AG3U	250mL unpres amber glass
AG3T	Na Thiosulfate 250mL bottle
BP18	Na Thiosulfate Amber bottle
AG1T	Na Thiosulfate 1L Amber
AG1A	Fig 2 Chemical Blood

Sender Initials

Additional Comments

309 000

WO#: 70395568

PM: LAB

Due Date: 12/18/25

CLIENT: INTER-LATHAM

Client Name:

Project #

Courier: ☐ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace ☐ Other

Tracking #:

Custody Seal on Cooler/Box Present: ☐ Yes ☒ No Seals intact: ☐ Yes ☒ No Temperature Blank Present: ☐ Yes ☒ No
Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ Ziploc ☒ None ☐ Other Type of Ice: Wet Blue ☒ None

Thermometer Used: TH211 Correction Factor: +1 ☐ Samples on ice, cooling process has begun
Cooler Temperature(°C): 18.1 Cooler Temperature Corrected(°C): 18.2 Date/Time 5035A kits placed in freezer _____

Temp should be above freezing to 6.0°C

USDA Regulated Soil ☒ N/A, water sample)

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or
VA (check map)? ☐ Yes ☒ No

Did samples originate from a foreign source including Hawaii and Puerto Rico)? ☐ Yes ☒ No

If Yes to either question, fill out a Regulated Soil Checklist (ENV-FRM-MELV-0076) and include with SCUR/COC paperwork.

Date and Initials of person examining contents:

	COMMENTS:
Chain of Custody Present: ☒ Yes ☐ No	1.
Chain of Custody Filled Out: ☒ Yes ☐ No	2.
Chain of Custody Relinquished: ☒ Yes ☐ No	3.
Sampler Name & Signature on COC: ☒ Yes ☐ No ☐ N/A	4.
Samples Arrived within Hold Time: ☒ Yes ☐ No	5.
Short Hold Time Analysis (<72hr): ☐ Yes ☒ No	6.
Rush Turn Around Time Requested: ☐ Yes ☒ No	7.
Sufficient Volume: (Triple volume provided for MS/MSD) ☒ Yes ☐ No	8.
Correct Containers Used: ☒ Yes ☐ No	9.
-Pace Containers Used: ☒ Yes ☐ No	10.
Containers Intact: ☒ Yes ☐ No	11.
Filtered volume received for Dissolved tests ☐ Yes ☒ No ☐ N/A	Note: if sediment is visible in the dissolved container.
Sample Labels match COC: ☒ Yes ☐ No	12.
-Includes date/time/ID/Analysis Matrix: SL ☒ WT ☐ OIL OTHER	

Date and Initials of person checking preservation:

All containers needing preservation have been ☒ Yes ☐ No ☐ N/A	13. ☐ HNO ₃ ☐ H ₂ SO ₄ ☐ NaOH ☐ HCl
pH paper Lot # <u>210525</u>	Sample #
All containers needing preservation are found to be in compliance with method recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH>9 Sulfide, ☒ Yes ☐ No ☐ N/A NAOH>12 Cyanide)	
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water).	
Per Method, VOA pH is checked after analysis	Initial when completed: Lot # of added preservative: Date/Time preservative added:
Samples checked for dechlorination: ☐ Yes ☐ No ☒ N/A	14.
KI starch test strips Lot #	Positive for Res. Chlorine? Y N
Residual chlorine strips Lot #	15.
SM 4500 CN samples checked for sulf ☐ Yes ☐ No ☒ N/A	Positive for Sulfide? Y N
Lead Acetate Strips Lot #	16.
Headspace in ALK Bottle (>6mm): ☐ Yes ☐ No ☒ N/A	17.
Headspace in VOA Vials (>6mm): ☐ Yes ☐ No ☒ N/A	
Trip Blank Present: ☐ Yes ☐ No ☒ N/A	
Trip Blank Custody Seals Present ☐ Yes ☐ No ☒ N/A	

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Date/Time:

Comments/ Resolution:

* PM (Project Manager) review (which includes the SCUR) is documented electronically in LIMS.